

General notes:
 1. Do not scale drawings. Dimensions govern.
 2. All dimensions are in millimeters unless noted otherwise.
 3. All dimensions shall be verified on site before proceeding with work.
 4. HHbR Ltd shall be notified in writing of any discrepancies.

Specific notes:



- Wall Existing
- Wall Proposed
- Area Proposed
- Area Existing

- Escape Route
- ↓ Escape Stair
- Escape Direction
- ↻ Refuge Area
- ↻ Fire Escape
- Escape Route
- Escape Distance
- Fire Hydrant

- Fire Rating 30mins
- Fire Rating 60mins
- FD30 Door 30mins fire/smoke rating
- FD60 Door 60mins fire/smoke rating
- FW30 Window 30mins fire rating
- MFAP Main Fire Alarm Panel
- MCP Manual Call Point
- INT Fire Alarm Wireless Interface Unit
- SDR Sounder C/W Visual Indicator
- CSD Ceiling Smoke Detector
- CHD Ceiling Heat Detector

Ocp. Occupancy
 FFL Finish Floor Level

Notes:

1. All drawings to be confirmed by approved inspector.
2. All existing construction types to be confirmed and agreed on site by approved inspector and main contractor.
3. To be read in conjunction with M&E drawings.
4. To be read in conjunction with site strategy drawings.
5. All doors to plant rooms, stores and cleaner's cupboards to be kept locked shut.
6. All door clear width dimensions in mm.
7. Occupancy numbers based on 7p/sq.m

A 20/7/17 Courtyard added.
 Rev. Date Issue Details

HENLEY HALEBROWN RORRISON
 architects

21 Perseverance Works 38 Kingsland Road London E2 8DD
 Tel: 020 7033 9700 E-mail: studio@HHbR.co.uk

Title
**No. 94 Proposed
 Ground Floor Plan (Cafe)
 Fire Strategy**
 © HHbR Ltd. www.HHbR.co.uk

Client
Benyon Estate

Project
De Beauvoir Road

Date	Originator	Scale@A3	Scale@A1
18.07.17	JM	1:100	1:50

Status	Dwg. no. + Rev.
C Construction	9_1102_L_214_A

